TELETEK

DECLARATION OF CONFORMITY

We, **Teletek Electronics JSC**
Address: 2, Iliyansko shose Str.
1220 Sofia, Bulgaria

Declares that the

Product: **SensoIRIS MCP150**
Description: Intelligent analogue addressable fire alarm manual call point with built - in isolator module

Complies to the following standards:

EN 54-11:2001; EN 54-11:2001/A1:2005
EN 55032:2015
EN 50130-4:2011; EN 50130-4:2011/A1:2014
EN 54-17:2005; EN 54-17:2005/AC: 2007

The following Regulation:

CPR № 305/2011
REACH № 1907/2006

And the following Directives:

2014/30/EC – EMC
2011/65/EU – RoHS II

Additional information:

First date of production: 11.2011

Certificate:

№ 1293- CPR-0473 Rev.2 of September 29, 2023 from Notified body № 1293 EVPU
№ 1139f/01 Issue 02 of November 25, 2025 from Notified body 0832 BRE Global Limited

Test report:

№ C08/14/0026/4206/CA Rev.2 of September 29, 2023 from Notified body № 1293 EVPU
№ TE-125976-1000 Issue 1 of November 21, 2025 from Notified body № 0832 BRE Global Limited

2, Iliyansko shose Str.
1220 Sofia, Bulgaria
28.11.2025

Alek Artinyan
Quality Manager

ТЕЛЕТЕК ЕЛЕКТРОНИКС ЕАД * TELETEK ELECTRONICS JSC * СОФИЯ SOFIA

CE 15

1293