TELETEK

DECLARATION OF CONFORMITY

We, **Teletek Electronics JSC**
Address: 2, Iliyansko shose Str.
1220 Sofia, Bulgaria

Declares that the

Product: **SensoMAG MCP50**
Description: Conventional manual call point

Complies with the following standards:

EN 54-11:2001
EN 54-11:2001/A1:2005
EN 55032:2015

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU- EMC
2011/65/EU – RoHS II

Additional information:

First date of production: 2018
Certificate:
№ 1293–CPR-0655 Rev.1 of November 6th , 2023 from Notified body № 1293 EVPU
Test report:
№ C08/19/0006/4206/CA Rev.1 of November 6th , 2023 from Notified body № 1293 EVPU

2, Iliyansko shose Str.
1220 Sofia, Bulgaria
13.10.2025

Alek Artinyan
Quality Manager

ТЕЛЕТЕК ЕЛЕКТРОНИКС ЕАД * TELETEK ELECTRONICS JSC * СОФИЯ SOFIA

CE 19

1293