TELETEK

DECLARATION OF CONFORMITY

We, **Teletek Electronics JSC**
Address: 2, Iliyansko shose Str.
1220 Sofia, Bulgaria
Declares that the

Product: **SensoMAG S30**
Description: Conventional fire alarm optical-smoke detector

Complies to the following standards:

EN 54-7:2018
EN 55032:2015
EN 50130-4:2011; EN 50130-4:2011/A1:2014

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU - EMC
2011/65/EU – RoHS II

Additional information:
First date of production: 2008
Certificate:
№ 1293–CPR-0637-Rev.2 of November 6th, 2023 from Notified body № 1293 EVPU
Test report:
№ C08/22/0001/4204/CA-2 Rev.1 of November 6th, 2023 from Notified body № 1293 EVPU

Note: To be used in conjunction with base B12L/U, B24, B24D, B24RD or B24-HP.

2, Iliyansko shose Str.
1220 Sofia, Bulgaria
09.06.2025

ТЕЛЕТЕК ЕЛЕКТРОНИКС ЕАД * TELETEK ELECTRONICS * СОФИЯ SOFIA

Alek Artinyan
Quality Manager

CE 09
1293