TELETEK

DECLARATION OF CONFORMITY

We, **Teletek Electronics JSC**
Address: 2, Iliyansko shose Str.
1220 Sofia, Bulgaria

Declares that the
Product: **IRIS8**
Big box - IRIS8 B, IRIS8 (1-8) B, iRIS8 (1-8) B
Small box - IRIS8 S, IRIS8 (1-8)L S, IRIS (1-4)L P, iRIS8 S
Extension box - IRIS8 S Ext, IRIS (1-8) Ext, iRIS8 S Ext

Description: Expandable Addressable Fire Alarm Control Panel IRIS8 Series

Complies with the following standards:

EN 54-2:1997; EN 54-2:1997/AC:1999; EN 54-2:1997/A1:2006
EN 54-4:1997; EN 54-4:1997/AC:1999; EN 54-4:1997/A1:2002
EN 54-4:1997/A2:2006
EN IEC 62368-1:2018
EN 55032:2015; EN 55032:2015/A11:2020 (Class A)
EN IEC 61000-3-2:2019
EN 61000-3-3:2013; EN 61000-3-3:2013/A1:2019
EN 50130-4:2011; EN 50130-4:2011/A1:2014

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU- EMC
2014/35/EU- LVD
2011/65/EU- RoHS II

Additional information:

First date of production: 03.2021

Certificate:
№ 1293-CPR-0790 Rev.1 of November 6th , 2023 from Notified body № 1293 EVPU

Test report:
№ C08/20/0033/4202,4206/SL Rev.1 of November 6th , 2023 from Notified body № 1293 EVPU

2, Iliyansko shose Str.
1220 Sofia, Bulgaria
09.06.2025

Alek Artinyan
Quality Manager

ТЕЛЕТЕК ЕЛЕКТРОНИКС ЕАД * TELETEK ELECTRONICS JSC * СОФИЯ SOFIA

CE 21

1293