NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0926

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of March 9th, 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Addressable module with one input
SensoIRIS MINP M, Belinda MINP M, Erida MINP M,
Marl MINP M, Smoke sense MINP M, Expera MINP M

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-18:2005, EN 54-18:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on December 6th, 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

EVPÚ, a.s. NOVÁ DUBNICA Notified Body No. 1293

Nová Dubnica, December 6th, 2024

Michal M i š i a k
Head of CB NB No. 1293

056196

© Tlačiareň cenín KASICO, a. s., Bratislava, KC24-00085

Annex to Certificate No. 1293 - CPR - 0926 from December 6th, 2024

General information

The SensoIRIS MINP M (and derived variants) is a compact module with one input. The module monitors and transfers to control panel the state of this input - state ON or state OFF.
The module is designed for built in installation in the mounting box of the device (PCB only); or it can be situated into a small plastic box for wall mounting.

Technical specifications

Operating voltage	15 ÷ 32 VDC
Permissible voltage ripple	3.0Vpp@27Vdc
Mounting	Indoor use

Essential characteristics	**Harmonised technical specification** **EN 54-18: 2005, EN 54-18: 2005/AC: 2007**	**Performance**
Response delay (response time)	cl. 5.2	Pass
Performance under fire conditions	cl. 5.1.4	Pass
Operational reliability	cl. 5.1.4	Pass
Durability of operational reliability and response delay: temperature resistance	cl. 5.3, 5.4	Pass
Durability of operational reliability: vibration resistance	cl. 5.8 to 5.11	Pass
Durability of operational reliability: humidity resistance	cl. 5.5, 5.6	Pass
Durability of operational reliability: corrosion resistance	cl. 5.7	Pass
Durability of operational reliability: electrical stability	cl. 5.2, 5.12	Pass

EVPÚ, a.s. NOVÁ DUBNICA Notified Body No 1293

Nová Dubnica, December 6th, 2024

Michal M i š i a k
Head of CB NB No. 1293